

Initial Notification of Applicability^b

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines

40 CFR Part 63 Subpart ZZZZ

RECEIVED
AUG 06 2013
Air Protection Division
(3AP10)

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for
Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): _____

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:

- Existing non-emergency compression ignition (CI) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: _____White Rock Silica Sand Company, Inc_____

Facility name (if different): _____

Facility (physical location) address: _____331 Methodist Road, Greenville PA 16125_____

My facility is a (please choose one): ☐ Major source ☒ Area source

Owner name/title: _____James Adzima, President_____

Owner/company address: _____331 Methodist Road, Greenville PA 16125_____

Owner telephone number: _____724-588-7020_____

This is an example of the type of information that must be submitted to fulfill the Initial Notification of Applicability Status requirement of 40 CFR 63, subpart ZZZZ. You may submit the information in another form or format, or you may use this form.

^b Initial Notification is due 120 days after the effective date of the rule or 120 days after you become subject to the rule

Owner email address (if available): _____

If the Operator information is different from the Owner, please provide the following:

Operator name/title: _____

Operator telephone number: _____

Operator email address (if available): _____

Brief description of the stationary RICE at the facility, including number of engines and the site-rated HP of each engine: _____ Our facility operates a sandstone crushing operation which is powered by (1) Diesel generator which is rated at 750HP with oxidation catalyst _____

I hereby certify that the information presented herein is correct to the best of my knowledge.

(Signature)

7/29/2013
(Date)

Troy Adzima, Vice President
(Name/title)

(814) 382-8178
(Telephone No.)

Submit the Initial Notification to the following offices:

Bureau of Air Quality
Department of Environmental Protection
230 Chestnut Street
Meadville, PA 16335

EPA Region III Director
Air Protection Division
1650 Arch Street
Philadelphia, PA 19103

